


ArcPixel Power - CE



QR code for user manual



USER MANUAL

Version 2.1

ArcPixel Power-CE

Table of contents

1. Important safety instructions	3
1. Consignes de sécurité importantes.....	4
2. Operating determinations.....	4
3. Description of the ArcPixel Power-CE.....	5
4. Installation.....	5
4.1. Connection to the mains:	5
4.2. Mounting the ArcPixel Power-CE	6
4.3. Connecting ArcPixes-CE.....	6
4.4. Connecting ArcDots-CE (ArcSource Outdoor 4MC Pixel-CE , ArcDotFlashes-CE) ..	9
6. Control menu map.....	14
5. ArcPixel Power-CE - DMX protocols.....	11
7. Control menu	16
7.1 DMX Addr (<i>Fixture addressing</i>)	16
7.2 Info (<i>Fixture information</i>)	16
7.3 Dots (<i>ArcDot/ArcPix settings</i>)	17
7.4 Personality	18
7.5 Test.....	18
7.6 Stand-alone	19
7.7 Special settings	19
8. Software update.....	19
9. Incorporation of new dots (after replacing faulty dots)	20
10. ArcPixel Power Web manager	23
11. Technical Specifications	25

CAUTION!
Unplug mains lead before opening the housing!

**FOR YOUR OWN SAFETY, PLEASE READ THIS USER MANUAL CAREFULLY
BEFORE YOU INITIAL START - UP!**

ATTENTION!
Débrancher l'appareil avant d'ouvrir le boîtier!

**POUR VOTRE SÉCURITÉ, LISEZ ATTENTIVEMENT CETTE NOTICE AVANT LA PRE-
MIERE UTILISATION**

1. Important safety instructions

Every person involved with installation and maintenance of this product has to:

- be qualified
- **follow the instructions and heed all warnings in this manual**

CAUTION!
***Be careful with your operations. With a high voltage you can suffer
a dangerous electric shock when touching the wires inside the unit!***

This product has left our premises in absolutely perfect condition. In order to maintain this condition and to ensure a safe operation, it is absolutely necessary for the user to follow the safety instructions and warning notes written in this manual.

WARNING
***To prevent injury, this apparatus must be securely installed in accordance with the
installation instructions."***

Do not block any ventilation openings. Install in accordance with the manufacturer's instructions.

Do not install near any heat sources such as radiators, heat registers, stoves, or other apparatus (including amplifiers) that produce heat.

Do not use this apparatus near water. Clean only with dry cloth.

Only use attachments/accessories specified by the manufacturer.

Protect the power cord from being walked on or pinched particularly at plugs, convenience receptacles, and the point where they exit from the apparatus.

Refer all servicing to qualified service personnel. Servicing is required when the apparatus has been damaged in any way, such as power-supply cord or plug is damaged, liquid has been spilled or objects have fallen into the apparatus, the apparatus has been exposed to rain or moisture, does not operate normally, or has been dropped.

Use a source of AC power that complies with local building and electrical rules. AC power has to have both overload and short circuit protection.

***This device falls under protection class I. Therefore the ArcPixel Power-CE has to be
connected to a mains socket outlet with a protective earthing connection!***

This device is for professional use only. It is not for household use.

***Warning: Operation of this equipment in a residential environment could cause
radio interference.***

Resistance of the equipment is designed for electromagnetic environments E1, E2, E3 according to the standard EN55103-2 ed.2 Electromagnetic compatibility. Product family standard for audio, video, audiovisual and entertainment lighting control apparatus for professional use. Part 2: Immunity.

The installation company should measure levels of possible interferences above the tested levels E1, E2, E3 given by this standard (e.g. transmitters in surrounding area) before installing the equipment.

Emission of the equipment complies with the standard EN55032 Electromagnetic compatibility of multimedia equipment – Emission Requirements according to class A.

1. Consignes de sécurité importantes

Toute personne impliquée dans l'installation et la maintenance de ce produit doit:

- Être suffisamment qualifié
- Suivre les instructions de ce manuel

ATTENTION!

Soyez prudent avec vos manipulations. Avec une haute tension, vous risquez un choc électrique en touchant les fils à l'intérieur de l'appareil!

Ce produit a quitté nos ateliers dans un état irréprochable. Afin de maintenir cet état et pour assurer un bon fonctionnement, il est absolument nécessaire de suivre les consignes de sécurité et les notes contenues dans ce manuel.

AVERTISSEMENT

Pour éviter toute blessure, cet appareil doit être solidement fixé à en conformité avec les instructions d'installation. "

Ne pas bloquer les ouvertures de ventilation. Installer conformément aux instructions du fabricant.

Ne pas installer près de sources de chaleur telles que radiateurs, ou autres appareils (y compris les amplificateurs) produisant de la chaleur.

Ne pas utiliser cet appareil près de l'eau. Nettoyer avec un chiffon sec.

Une prise de branchement ou un coupleur est utilisé comme dispositif de déconnexion, ce dispositif doit rester facilement accessible.

N'utilisez que des accessoires spécifiés par le fabricant.

Protégez le cordon d'alimentation du piétinement ou pincement, particulièrement au niveau des fiches, des prises, et le point où ils sortent de l'appareil

Confiez toute réparation à un personnel qualifié. Une réparation est nécessaire lorsque l'appareil a été endommagé de quelque façon que ce soit. cordon d'alimentation, fiche est endommagé, liquide renversé à l'intérieur, ou des objets sont tombés dans l'appareil, l'appareil a été exposé à la pluie ou à l'humidité, ne fonctionne pas normalement, ou s'il est tombé.

Utilisez une source de courant alternatif qui est conforme à l'endroit où vous vous trouvez. La source alternative doit avoir à la fois une protection de surcharge et de court-circuit.

Ce dispositif relève de la classe de protection I. Par conséquent, la ArcPixel Power-CE doit être connecté à une prise électrique reliée à la terre!

2. Operating determinations

This product was designed for indoor use only.

If the unit has been exposed to drastic temperature fluctuation (e.g. after transportation), do not switch it on immediately. The arising condensation water might damage your unit. Leave the unit switched off until it has reached room temperature.

Avoid brute force when installing or operating the unit.

When choosing the installation spot, please make sure that the unit is not exposed to extreme heat, moisture or dust.


Only operate the unit after having checked that the housing is firmly closed and all screws are tightly fastened. The maximum ambient temperature 40° C must never be exceeded.

Operate the unit only after having familiarized with its functions. Do not permit operation by persons not qualified for operating the unit. Most damages are the result of unprofessional operation!

Please use the original packaging if the product is to be transported.

Please consider that unauthorized modifications on the unit are forbidden due to safety reasons!

3. Description of the ArcPixel Power-CE



4. Installation

CAUTION!

These servicing instructions are for use by qualified service personnel only. To reduce the risk of electric shock do not perform any servicing other than that contained in the operating instructions unless you are qualified to do so.


4.1. Connection to the mains:

The ArcPixel Power-CE is equipped with auto-switching power supply that automatically adjusts to any 50-60Hz AC power source from 100-240 Volts. The fixture must be grounded. Connect the fixture to the mains with enclosed power cord.


This device falls under protection class I. Therefore the ArcPixel Power-CE has to be connected to a mains socket outlet with a protective earthing connection.

4.2. Mounting the ArcPixel Power-CE

The ArcPixel Power-CE should be placed on a non-flammable flat surface in any orientation and fixed by the four screws. There are four mounting holes of a dimension of 5x7 mm in housing of the driver. Ensure that installation place is enough ventilated.



4.3. Connecting ArcPixes-CE



Connect ArcPixes to the LED outputs of the ArcPixel Power-CE. The first ArcPix in the ArcPix chain can be connected to the screw terminal board on the ArcPixel Power-CE either via connection box or via customized cable length (has to be specified at order). Maximum length between the ArcPixel Power-CE and the last ArcPix must not exceed 100 metres. For larger installation, the ArcPixel Power-CE should be connected to the Robe Media Server which allows automatic pixel mapping and full control of the ArcPixes modules.

Placing ferrites


The ferrite CSA19/9.4/29-4S60-EN (P/N 13051312) with one turn of the flat cable has to be placed on the cable at each ArcPix output of the ArcPixel Power-CE, and this ferrite (without cable turn - cable goes directly through ferrite, ferrite cover is snapped only) has to be placed after each thirtieth ArcPix in the ArcPix line (e.g. 100 ArcPixes per output = 3 ferrites in a line + 1 ferrite with a cable turn at the ArcPix output). You should count 100mm of the cable length per one cable turn on ferrite.

The ArcPix line ferrites (between ArcPixes) have to be placed on the flat cable before mounting of ArcPixes on an installation surface.



To connect ArcPixes CE

1. Disconnect ArcPixel Power-CE from mains.
2. Connect ArcPixes (with ferrites as described above) to the ArcPixel Power-CE. Max load per output is 100 ArcPixes.
Connect the termination box ArcPix to each ArcPix line. If you use Artnet for control of the ArcPixel Power-CE, you can connect ArcPixes to all LED outputs 1-4.
For larger installation we recommend to set different universes for each ArcPix output. The first ArcPix has to have the bottom universe and the last ArcPix the top universe (requirement of the Robe Media Server).
3. Connect ArcPixel Power-CE to mains.
4. Run procedures " Search Dots" and " Sort Dots" from the menu "Dots".
5. Save adjusted values with the option "Store Config".
7. Connect the ArcPixel Power-CE the Robe Media Server. Set another needed items in the ArcPixel Power-CE menu.



Number of needed ferrites:
 - each ArcPix line: 4 (between ArcPixes no.30-31, 60-61, 90-91, at ArcPixel Power)
 - total for installation: 16

Note: Never connect/disconnect LED modules when the ArcPixelPower-CE is under voltage!

Every ArcPix line has to be terminated with the termination box ArcPix!


If the line between ArcPixes is disconnected, the ArcPixes behind point of interrupt will not work. Before restoring connection between ArcPixes, switch off the ArcPixel Power-CE.

In case that some ArcPix has been changed, the same address as had original ArcPix is assigned to the new ArcPix by the ArcPixel Power-CE. **It is very important to save Dots configuration at every change of ArcPixes.**(Menu "Dots" -> "Store Config"),

Max. cable length between the ArcPixel Power-CE and the last connected ArcPix module should not exceed **100m**

Note: If DMX is used for control of the ArcPixel Power-CE, the LED outputs 1-3 may be used only.

(In this case, one UART from four available UARTs is used for DMX input and remaining three UARTs can be used for LED outputs only. LED output load is the same as in a case of the control by Artnet - max 100 LED modules per LED output, but max. 300 modules per fixture).



Every ArcPix line has to be terminated with the termination box ArcPix.

The Robe Media Server allows to choose two modes of ArcPixes connection: Fixed-wiring mode and Picture mode. For detailed description see the user manual of the Robin Media Server.

4.4. Connecting ArcDots-CE (ArcSource Outdoor 4MC Pixel-CE , ArcDotFlashes-CE)

Connect ArcDots to the LED outputs of the ArcPixel Power-CE. The ArcDots can be interconnected directly or by using T- connectors - see the picture below. If you use Artnet for control of the ArcPixel Power-CE, you can connect ArcDots to all LED outputs 1-4.

For larger installation (more than 25 ArcDots), the ArcPixel Power-CE should be connected to the Robe Media Server which allows automatic pixel mapping and full control of the ArcDots modules. Without Robe Media Server, you have to perform pixel mapping manually using the menu "Dots".


Placing ferrites

The ferrite GTFC 16-8-16 (P/N 1305 1703) has to be placed on the cable at each ArcDot output of the ArcPixel Power-CE.




To connect ArcDots

1. Disconnect ArcPixel Power-CE from mains.
 2. Connect ArcDots (with ferrites as described above) to the ArcPixel Power-CE. Max. number of ArcDots per output is 35. Connect active terminators to each ArcDots line.
 3. Connect the ArcPixel Power-CE to mains
 4. Run procedures "Search Dots" and "Sort Dots" from the menu "Dots"
 5. Save adjusted values with the option "Store Config"
 6. Disconnect the ArcPixel Power-CE from mains and replace active terminators by passive terminators*.
 7. Connect the ArcPixel Power-CE to mains and to the Robe Media Server. Set another needed items in the ArcPixel Power-CE menu.
- * Active terminators can remain permanent connected if there is place for them (they are bigger than passive ones).



The minimum cable length of 0.3m between two T-connectors has to be kept in case that the pixel sorting is executed from the ArcPixel Power-CE menu.



Every ArcDot line has to be terminated with the passive terminator!

Note: Never connect/disconnect LED modules when the ArcPixelPower-CE is under voltage!


If the line between ArcDots is disconnected, the ArcDots behind point of interrupt will not work. Before restoring connection between ArcDots, switch off the ArcPixel Power-CE.

In case that some ArcDot has been changed, the same address as had original ArcDot is assigned to it by the ArcPixel Power-CE. **It is very important to save ArcDots configuration at every change of an ArcDot.** (Menu "Dots" -> "Store Config"),

Max. cable length between ArcPixel Power-CE and the last connected ArcDot module should not be exceeded: **100m @ 25 ArcDots per LED output** or **65 m @ 35 ArcDots per LED output**. Only one ArcDot can be connected to the T-connector.

Note: If DMX is used for control of the ArcPixel Power-CE, the LED outputs 1-3 may be used only.

(In this case, one UART from four available UARTs is used for DMX input and remaining three UARTs can be used for LED outputs only. LED output load is the same as in a case of the control by Artnet - max 35 LED modules per LED output, max. 100 modules per ArcPixel Power-CE).



Every ArcDot line has to be terminated with the passive terminator!

Note: the same rules as for the ArcDots-CE go for the ArcSource Outdoor 4MC Pixels-CE and ArcDotFlashes-CE with the following exception for the ArcDotFlashes-CE: If no DMX signal is present at ArcPixel Power-CE, the ArcDotFlash modules flash randomly (22-28 flashes per minute).

The Robe Media Server allows you to choose two modes of ArcDots connection: Fixed-wiring mode and Picture mode. For detailed description see the user manual of the Robin Media Server.

5. ArcPixel Power-CE - DMX protocols

ArcDot-CE/ ArcSource Outdoor 4MC Pixel -CE

version 1.1

RGBW mode=Off (Channel)	RGBW* mode=On (Channel)	Value	Function	Type of control
ArcDot 1/ ArcSource Outdoor 4MC Pixel 1				
1	1	0-255	Red Red LED saturation control (0-100%)	proportional
2	2	0-255	Green Green LED saturation control (0-100%)	proportional
3	3	0-255	Blue Blue LED saturation control (0-100%)	proportional
-	4	0-255	White White LED saturation control (0-100%)	proportional
ArcDot 2/ ArcSource Outdoor 4MC Pixel 2				
4	5	0-255	Red Red LED saturation control (0-100%)	proportional
5	6	0-255	Green Green LED saturation control (0-100%)	proportional
6	7	0-255	Blue Blue LED saturation control (0-100%)	proportional
-	8	0-255	White White LED saturation control (0-100%)	proportional
ArcDot 3/ ArcSource Outdoor 4MC Pixel 3				
7	9	0-255	Red Red LED saturation control (0-100%)	proportional
8	10	0-255	Green Green LED saturation control (0-100%)	proportional
9	11	0-255	Blue Blue LED saturation control (0-100%)	proportional
-	12	0-255	White White LED saturation control (0-100%)	proportional
ArcDot 100/ ArcSource Outdoor 4MC Pixel 100				
298	397	0-255	Red Red LED saturation control (0-100%)	proportional
299	398	0-255	Green Green LED saturation control (0-100%)	proportional
300	399	0-255	Blue Blue LED saturation control (0-100%)	proportional
-	400	0-255	White White LED saturation control (0-100%)	proportional

* RGBW modules only

ArcPix-CE

version 1.0

Channel	Value	Function	Type of control
ArcPix 1			
1	0-255	Red Red LED saturation control (0-100%)	proportional
2	0-255	Green Green LED saturation control (0-100%)	proportional
3	0-255	Blue Blue LED saturation control (0-100%)	proportional
ArcPix 2			
4	0-255	Red Red LED saturation control (0-100%)	proportional
5	0-255	Green Green LED saturation control (0-100%)	proportional
6	0-255	Blue Blue LED saturation control (0-100%)	proportional
ArcPix 3			
7	0-255	Red Red LED saturation control (0-100%)	proportional
8	0-255	Green Green LED saturation control (0-100%)	proportional
9	0-255	Blue Blue LED saturation control (0-100%)	proportional
: ArcPix 100			
298	0-255	Red Red LED saturation control (0-100%)	proportional
299	0-255	Green Green LED saturation control (0-100%)	proportional
300	0-255	Blue Blue LED saturation control (0-100%)	proportional
: ArcPix 170			
508	0-255	Red Red LED saturation control (0-100%)	proportional
509	0-255	Green Green LED saturation control (0-100%)	proportional
510	0-255	Blue Blue LED saturation control (0-100%)	proportional

ArcDotFlash-CE

version 1.1

Channel	Value	Function	Type of control
ArcDotFlash 1			
1	0-127	Strobe	
	128	Synchronous flashing from slow to fast (0.02Hz-20Hz)	proportional
	129-255	Permanent lit	step
2	0-127	Random flashing from slow to fast (2.2 flashes/minute-28 flashes/minute)	proportional
	128	Dimmer	
	129-255	Light intensity from 0% to 100%	proportional
ArcDotFlash 2			
3	0-127	Strobe	
	128	Synchronous flashing from slow to fast (0.02Hz-20Hz)	proportional
	129-255	Permanent lit	step
4	0-127	Random flashing from slow to fast (2.2 flashes/minute-28 flashes/minute)	proportional
	128	Dimmer	
	129-255	Light intensity from 0% to 100%	proportional
:			
ArcDotFlash 100			
199	0-127	Strobe	
	128	Synchronous flashing from slow to fast (0.02Hz-20Hz)	proportional
	129-255	Permanent lit	step
200	0-127	Random flashing from slow to fast (2.2 flashes/minute-28 flashes/minute)	proportional
	128	Dimmer	
	129-255	Light intensity from 0% to 100%	proportional

6. Control menu map


Default settings=**Bold print**

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7
DMX Addr	Set DMX Address	0001-0512				
	IP Address	Default Address	Set Address			
		Custom Address	IP Adr 1	0-255		
			IP Adr 2	0-255		
			IP Adr 3	0-255		
			IP Adr 4	0-255		
			Set Address			
	Network mask	Net M. 1				
		Net M. 2				
		Net M. 3				
		Net M. 4				
		Set Net M.				
Info	Software Version					
	IP Addr.					
	MAC Addr.					
	Dots	New Dots				
		Unknown Dots				
Dots	Search Dots					
	Sort Dots	Auto Sort				
		Manual Sort				
		Restore Last				
	Fade Time	Off				
		0.1s-25.5s				
	Dots Curve	D. Curve	0-255			
	RGBW 4ch Mode	On, Off				
	Order Mode	Order Compact				
		Order Universe				
	Store Config					
	Test Dots					
	Update Dots	No				
		Yes				
Personality	ArtNet Universe	Uni. 1	0-255			
		Uni. 2	0-255			
		Uni. 3	0-255			
		Uni. 4	0-255			
	DMX Input	Ethernet				
		Wired DMX				
	Display Settings	Disp Off Timer	Off, On			
		Display Lightnes	0-100%			
		Display Contrast	0-100%			
	Skip Cfg Mismatch	Yes, No				
	Default Settings	Set Defaults				
Test	Single Dots					
	All Dots					
	Full Power					
Stand Alone	Play On Start	Off				
		Single				
		All				
		Full PWR				
		User P1				

Level 1	Level 2	Level 3	Level 4	Level 5	Level 6	Level 7
		User P2				
		User P3				
	Program Play	User 1				
		User 2				
		User 3				
	Program Edit	User 1				
		User 2				
		User 3	S.Count	1-35		
			Step 1	Red Z1	0-255	
			:	Green Z1	0-255	
			Step 35	Blue Z1	0-255	
				White Z1	0-255	
				:		
				Red Z4	0-255	
				Green Z4	0-255	
				Blue Z4	0-255	
				White Z4	0-255	
				Step Tim.	0-25.5sec	
				Copy To Next		
Special Settings	Software Update	No, Yes				
	Reset Password					

7.Control menu

The control panel situated on the top cover of the ArcPixel Power-CE allows fixture addressing and set the driver's behaviour.



Control elements:

-  [ENTER] button- enters menu, confirms adjusted values and leaves menu.
-  [UP] button and [DOWN] button- moves between menu items on the the same level, sets values.
-  [ESCAPE] button- leaves the menu without saving value.

7.1 DMX Addr (*Fixture addressing*)

Set DMX Address - use this menu item to set the DMX start address of the fixture, which is defined as the first channel from which the ArcPixel Power-CE will respond to the DMX controller.

IP address - select this menu item to set desired IP address. IP address is the Internet protocol address. The IP uniquely identifies any node (fixture) on a network. There cannot be 2 fixtures with the same IP address on the network!

Default Address. This address is derived from fixture's MAC address and cannot be changed. Confirm the item "**Set Address**" to select this address.

Custom Address. IP address consists of four decimal numbers, each ranging from 0 to 255, separated by dots, e.g., 172.16.254.1. Each part represents a group of 8 bits (octet) of the address.

The following items "**IP Adr 1**", "**IP Adr 2**", "**IP Adr 3**", "**IP Adr 4**" allow to set each part (number) of the address. After setting desired IP address, confirm the item "**Set Address**" to save this address.

Network mask - select this menu item to set desired network mask. A network mask is a 32-bit mask used to divide an IP address into subnets and specify the networks available hosts.

The following items "**Net M.1**", "**Net.M.2**", "**Net.M.3**", "**Net.M.4**" serve for setting of each part (number) of the net mask.

After setting desired network mask, confirm the item "**Set Net M.**" to save adjusted values.

7.2 Info (*Fixture information*)

Use this menu to read useful information about the fixture.

Software version - select this menu item to read software versions.

Dot 10.0/20 - Dot version. The items show software version of each LED module.

MA. In - Driver version. The item shows software version of the ArcPixel Power-CE.

IP Addr - this menu item shows the current IP address.

MAC Addr - select this menu item to read the MAC address (the MAC address "runs" on display).

Dots - select this menu item to read information about connected LED modules (ArcDot, ArcPix)

New Dots - the item shows the number of recently connected LED modules.

Unknown Dots - the item shows the number of LED modules which were not detected by the dot checking procedure ("Search Dots") or are new dots after replacement.

7.3 Dots (ArcDot/ArcPix settings)

Use this menu to prepare LED module for operation in desired matrix.

Search Dots - this function checks all LED modules connected to the fixture and the message "Done" with the number of found LED modules is displayed after finishing the procedure.

Example: Dots: 25
 Search/Done

The ArcPixes, ArcDots are sorted according to their RDM UID in colour range RGB,RGB.....RGB.

Sort Dots - this menu allows you to choose automatic or manual sorting of connected LED modules.

Auto Sort - Connected LED modules are sorted automatically by the following rule:

ArcPix modules are sorted according to their IDs.

ArcDot modules are sorted according to their distances from the ArcPixel Power-CE (the active terminator for the ArcDot has to be connected to the last ArcDot at each LED output of the ArcPixel Power-CE).

Manual Sort - after choosing this option, the following screen will be displayed:

Example: D001 St1 (D001...LEDE module No.1, St1.... LED output 1 of the ArcPixel Power-CE)
 U1 A001 (U1.....universe, A001.....DMX address)

You can go throw connected dots pressing the [UP] and [DOWN] buttons, current displayed LED module starts blinking a white colour.

Press the [ENTER], item U1 starts to blink slowly. Now by means of the [UP] and [DOWN] buttons you can move between the item A001 and U1. To edit selected item, press the [ENTER] again, selected item will start to blink fast and you can set desired values using the UP] and [DOWN] button.

After automatic or manual sorting, do not forget to save changes by means of the menu item „Store Config“.

Restore Last - recalls last saved dots configuration.

Fade Time - select this menu item to set a desired max. fade time (0-25.5 sec.). This adjusted fade time influences fade of RGB and dimmer during DMX operation:


If time between two receiving DMX values is > than fade time set in the item "Fade Time", the entire adjusted fade time will be used.

If time between two receiving DMX values is < than fade time set in the item "Fade Time", the adjusted fade time will be reduced to fill entire time between the two receiving DMX values.

e.g. "Fade Time".=2sec. and fixture has received Red=0 DMX, after 5 seconds will receive Red=255 DMX. It means, that red will go to full intensity during 2 seconds.

"Fade Time "=8 sec. and fixture has received Red=0 DMX, after 5 seconds will receive Red=255 DMX. It means, that red will go to full intensity during 5 seconds. (Max, fade time is reduced from 8 sec. to 5 sec.).

Dots Curve - this menu item allows you to select desired running of colour saturation. You can select 255 colour saturation runnings in all. The value 0 corresponds linear curve, the value 128 corresponds exponential curve with index 1.9 and last value 255 corresponds exponential curve with index 2.6.



RGBW 4ch Mode - This function activates four channels RGBW mode (see DMX protocol) - for RGBW modules only.

Order Mode - the menu allows to select a method how LED modules will be assigned to the Artnet Universe.

Order Compact - All LED modules will be assigned to the Universe at the first LED output. After filling this Universe, the rest of LED modules will be assigned to the Universe at the LED output 2.

Order Universe - LED modules output will be assigned to different Universes. LED modules on the first LED output to the Universe set at this LED output. LED modules on the second LED output to the Universe set at the second LED output etc.

Store Config - select this function to save all changes that have been done in the menu "Dots" .

Test Dots - use this menu item to browse through the list of sorted LED modules. The ID of corresponding dot is shown under the dot number. Displayed LED module blinks in white.

Update Dots - allows update of the connected LED modules after standard software updating of the ArcPixel Power-CE (item "Software Update" in the menu "Special Setting").

Note: The update via the menu "Software Update" has to be realized before running the "Update Dots" procedure

7.4 Personality

Use this menu to modify the ArcPixel Power-CE operating behavior.

ArtNet Universe - use the menu item to assign ArtNet universe to desired LED output.

Uni.1 - ArtNet universe for LED output 1

:

Uni.4 - ArtNet universe for LED output 4

ArtNet is a proprietary protocol for transmitting DMX512 (with RDM) over UDP/IP. Up to sixteen DMX512 universes can be accessed through one IP subnet. The Universe is a single DMX 512 frame of 512 channels.

DMX Input - this menu allows you to choose desired DMX data input:

Artnet - if this input is selected (RJ45), all LED outputs (1-4) are active.

Wired DMX - if this input is selected (3-pin XLR), only LED outputs 1-3 are active.

Display Settings - this menu allows you to change the display settings.

Display Off Timer - if this item is on the display will be switched off 2 minutes after last pressing any button on the control panel.

Display Lightness - select this menu item to adjust the display intensity (0-100%).

Display Contrast - select this menu item to adjust contrast of the display (0-100%).

Skip Cfg Mismatch - If this function regards behaviour of the fixture if some dots have been replaced (e.g. due to faulty dots).

No: after switching the fixture on, the channel with the new dots will be displayed and dots check procedure will stop. You have to manually assign new dots.

Yes: after switching the fixture on, the dots checking procedure will run and error messages regards replaced dots will appear (in case that some problem occurred). Fixture menu is accessible.

Default setting - select this option to set fixture personalities to the default (factory) values.

7.5 Test

Single Dots - the LED modules blink one by one starting from DMX address 1 (universe 1) in the colour order red, green, blue and white.

All Dots - all connected LED modules blink together in the colour order red, green, blue and white.

Before both test sequences, the "Search Dots" and "Sort Dots" procedures from the menu "Dots" have to be made.

Full Power - all connected LED modules light at max light output (R+G+B+W=full).

7.6 Stand-alone

The ArcPixel Power is not connected to the Robe Media Server but can execute pre-set programs (sequences).

Play On Start - This function allows you to select a program which will be played after switching the fixture on. Selected program will be played continuously in a loop.

Off - function is disabled.

Single - LED modules blink one by one in the colour order red, green, blue and white.

All - all connected LED modules blink together in the colour order red, green, blue and white.

Full PWR - all connected LED modules light at max light output (R+G+B+W=full).

User P1 - the ArcPixel Power plays user program 1.

User P2 - the ArcPixel Power plays user program 2.

User P3 - the ArcPixel Power plays user program 3.

Program Play - entering this menu provides a complete overview of all programs offered, from which the selected program can run continuously in a loop .

User 1 - the ArcPixel Power plays user program 1.

User 2 - the ArcPixel Power plays user program 2.

User 3 - the ArcPixel Power plays user program 3.

Program Edit - the ArcPixel Power offers three freely editable programs each up 35 steps. Every program step includes a step time-the total time occupied by the step in the program.

To edit a program

1. Use the [UP] and [DOWN] buttons to select desired program (User 1-User 3) and press the [ENTER] button.
2. Enter the item S. Count and by means of the [UP] and [DOWN] buttons set desired number of program steps. This value should be set before starting of programming (e.g. if you want to create a program with 10 steps, set S. Count=10).
- 3 Press the [ENTER] button.
- 4.Select Step 1 and press the [ENTER] button. List of editable items will appear:
 - Red Z1 - a red LEDs on LED output 1
 - Green Z1 - a green LEDs on LED output 1
 - Blue Z1 - a blue LEDs on LED output 1
 - White Z1 - a white LEDs on LED output 1
 - :
 - Red Z4 - a red LEDs on LED output 4
 - Green Z4 - a green LEDs on LED output 4
 - Blue Z4 - a blue LEDs on LED output 4
 - White Z4 - a white LEDs on LED output 4
 - Step Tim. - a step time (0-25.5 sec)
 - Copy To Next - this item duplicates the current prog. step to the next prog. step.
5. After editing the items, select next prog. step and edit its items again. Repeat this action for all program steps.

7.7 Special settings

Reset Password - using this function you can reset current password into default password: admin.

8. Software update

The Ethernet input (RJ45) also serves for software update of the fixture by means of the ROBE RDM Uploader software.

For more details about the ROBE RDM Uploader, please visit <https://www.robe.cz/robe-uploader/>.

9. Incorporation of new dots (after replacing faulty dots)

In case that some faulty dots have been replaced with the new dots, the following error message will appear after switching the fixture on:

"Ch. 1 Cfg Mismatch" - it means new dots at LED output 1

"Ch. 2 Cfg Mismatch" - it means new dots at LED output 2


"Ch. 3 Cfg Mismatch" - it means new dots at LED output 3

"Ch. 4 Cfg Mismatch" -it means new dots at LED output 4

You have to use the special procedure to incorporate new dots into existing dot lines.

There is an example of this procedure for the following dots connection:

The dots are connected to the ArcPixel Power and the 5 dots have been replaced (dot 1,2, at output 1 and dot 1,2,3 at output 2).




After switching the ArcPixelPower on, the following message will appear "Ch. 1 Cfg Mismatch".


1. Press the [ENTER] to enter menu "New Dot" and use the [UP] and [DOWN] to browse items Sel 1, Sel 2 (appropriate dot lights in green) - pictures (1),(2).

2. Select the dot 2 and press the [ENTER] to enter menu "Miss Dot". The Dot 2 starts flashing in green and by means of items Sel 1, Sel 2 select the following colour combination of dots when the blue dot will be after the dot 2-picture (3). The situation on picture 4 is not correct, the blue dot is not closely to green dot.


Note: The replaced dot flashes in green and the dot before this dot (near to the ArcPixelPower) has to be in red and the dot after the flashing dot has to be in blue. The red and blue dots have to be closely to the green dot (not second or the third dot). At least one position of colour dot (red or blue) has to be always kept.




In case of dot 2 on picture (3) you can select only variant with the blue dot after the green dot because the dot 1 has not been incorporated to the dot line yet and cannot shine in red colour.




3. Press the [ENTER] to go back to the menu "New Dot" and select dot 1 and press the [ENTER] to enter the menu "Miss Dot". The Dot 1 starts flashing in green and by means of items Sel 1, Sel 2 select the following colour combination of dots when the blue dot will be after dot 1-picture (5).
4. Press the [ENTER] to go back to the menu "New Dot" and using items Sel 1, Sel 2 you can see incorporated dots -picture (6), (7).




The blue dot is not closely to the green dot




5. Select the item "Check channel", press the [ENTER] and after dot checking procedure the message "Ch. 2 Cfg Mismatch" will appear. Press the [ENTER] to enter menu "New Dot" and use the [UP] and [DOWN] to browse items Sel 1, Sel 2 Sel 3 (appropriate dot lights in green) - pictures (8),(9), (10).




6. Select the dot 10 and press the [ENTER] to enter menu "Miss Dot". The Dot 10 starts flashing in green (picture (11) and by means of items Sel 1, Sel 2, Sel 3 select the following colour combination of dots when the blue dot will be after dot 10-picture (12). The blue dot 11 lights at LED output 3 because in this situation dots behave like one dot chain (from dot 16 to dot 1).
7. Press the [ENTER] to go back to the menu "New Dot" and select dot 9 (picture 13) and press the [ENTER] to enter the menu "Miss Dot". The Dot 9 starts flashing in green.



8. By means of items Sel 1, Sel 2, Sel 3 select the following colour combination of dots when the blue dot will be after dot 9-picture (14).
9. Press the [ENTER] to go back to the menu "New Dot" and select dot 8 (picture 15) and press the [ENTER] to enter the menu "Miss Dot". The Dot 8 starts flashing in green and by means of items Sel 1, Sel 2, Sel 3 select the following colour combination of dots when the blue dot will be after the dot 8 and the red dot before the dot 8-picture (16).



10. Press the [ENTER] to go back to the menu "New Dot and using items Sel 1, Sel 2, Sel 3 you can see incorporated dots -picture (17), (18), (19). you can see correct combination of pixels red, green, blue.




10. Select the item "Check channel" , press the [ENTER] and after dot checking procedure the message "Store?" will appear. Select option "Yes" if you wish to save the dot changes.

10. ArcPixel Power Web manager

The ArcPixel Power includes built-in web interface allowing quick overview of its settings and connected dots and also their setting.

To enter The ArcPixel Power Web manager, type the IP address of the ArcPixel Power (e.g. 2.67.2.0) into your web browser. PC or notebook with internet browser has to be connected to the same ethernet network as the ArcPixel Power.

Tab MAIN



Tab DOTS

The screenshot shows the 'DOTS' tab in the ArcPix Power web interface. At the top, there's a navigation bar with 'MAIN', 'DOTS', 'SETTINGS', and 'TOOLS'. The 'DOTS' section includes a 'Dots info' area with statistics: 400 known dots, 100 dots in each of four universes. Below this is a 'Search dots' button. The 'Dots sorting' section has a 'Sort' button and a 'Save changes' button. The main area displays four channels (1-4), each with 100 dots. Each dot is represented by a small box containing its address and universe number.

DOTS

Dots info

Number of known dots: 400
Number of dots in universe 1: 100
Number of dots in universe 2: 100
Number of dots in universe 3: 100
Number of dots in universe 4: 100

[Search dots](#)

Dots sorting

Start automatic sort: [Sort](#)
Save changes: [Apply](#)

Channel 1 (100) Channel 2 (100) Channel 3 (100) Channel 4 (100)

0000036d Addr: 1 Univ: 1	0000036d Addr: 4 Univ: 1	0000036d Addr: 7 Univ: 1	0000036d Addr: 10 Univ: 1	0000036d Addr: 13 Univ: 1	0000036d Addr: 16 Univ: 1	0000036d Addr: 19 Univ: 1	0000036d Addr: 22 Univ: 1	0000036d Addr: 25 Univ: 1	0000036d Addr: 28 Univ: 1	0000036d Addr: 31 Univ: 1	0000036d Addr: 34 Univ: 1	0000036d Addr: 37 Univ: 1	0000036d Addr: 40 Univ: 1	0000036d Addr: 43 Univ: 1	0000036d Addr: 46 Univ: 1	0000036d Addr: 49 Univ: 1	0000036d Addr: 52 Univ: 1	0000036d Addr: 55 Univ: 1
0000036d Addr: 58 Univ: 1	0000036d Addr: 61 Univ: 1	0000036d Addr: 64 Univ: 1	0000036d Addr: 67 Univ: 1	0000036d Addr: 70 Univ: 1	0000036d Addr: 73 Univ: 1	0000036d Addr: 76 Univ: 1	0000036d Addr: 79 Univ: 1	0000036d Addr: 82 Univ: 1	0000036d Addr: 85 Univ: 1	0000036d Addr: 88 Univ: 1	0000036d Addr: 91 Univ: 1	0000036d Addr: 94 Univ: 1	0000036d Addr: 97 Univ: 1	0000036d Addr: 100 Univ: 1	0000036d Addr: 103 Univ: 1	0000036d Addr: 106 Univ: 1	0000036d Addr: 109 Univ: 1	0000036d Addr: 112 Univ: 1

Tab SETTINGS

The screenshot shows the 'SETTINGS' tab in the ArcPix Power web interface. It contains three sections: 'DMX settings' with a 'DMX address' input field (set to 1) and a 'DMX input' dropdown (set to 'ARTNET'), an 'Apply' button, 'ArtNET settings' with four 'ArtNET universe' input fields (set to 4, 3, 2, 1) and an 'Apply' button, and 'Password settings' with 'Old password' and 'New password' input fields and an 'Apply' button.

Settings

DMX settings

DMX address:
DMX input:

[Apply](#)

ArtNET settings

ArtNET universe 1:
ArtNET universe 2:
ArtNET universe 3:
ArtNET universe 4:

[Apply](#)

Password settings

Old password:
New password:

[Apply](#)

Tab TOOLS

The screenshot shows the 'TOOLS' tab in the ArcPix Power web interface. It features a 'DMX console' section with tabs for 'Universe 1', 'Universe 2', 'Universe 3', and 'Universe 4'. Below the tabs, there's a 'Page: 1' indicator and a large grid of 32 columns and 4 rows of input fields for DMX data. The first row contains numbers 1-32, and the subsequent rows contain binary digits (0s and 1s).

Tools

DMX console

[Universe 1](#) [Universe 2](#) [Universe 3](#) [Universe 4](#)

Page: 1

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

11. Technical Specifications

Power supply

Input voltage: 100-240 V AC, 50-60 Hz

Fuse: T 8A H 250V ~

Max. power consumption: 640W (power factor=0.98)

Control and programming

Protocols: USITT DMX-512, Artnet

2 row LED display

4 control buttons

3 free editable programs, up to 35 steps each

Output

Max. Output Voltage: 50V DC

ArcPix output: 4 x Sauro CGF 050M5, (panel terminal board, female) & 4 x Sauro CGM 050 M5 (male)

ArcDot output: 4 x Chogori CGRBB-03RFFS-SC8001(female)

Max. load per output: 100 x ArcPix or 35 x ArcDot-CE/ArcSource Outdoor 4MC-Pixel-CE /ArcDotFlash-CE

Total max. load of ArcPixel Power-CE: 400 x ArcPix-CE or 100 x ArcDot-CE/ ArcSource Outdoor 4MC Pixel-CE/ ArcDotFlash-CE

Maximum cable length between output of the ArcPixel Power-CE and the last connected LED module

ArcPix-CE: 100 m @ 100 ArcPixes per output;


ArcDot-CE/ ArcSource Outdoor 4MC Pixel-CE/ArcDotFlash-CE: 100 m @ 25 LED modules per output or 65 m @ 35 LED modules per output

Total heat dissipation


max. 2200 BTU/hr (calculated)

Connection

DMX 512: 3-pin male/female XLR




ArtNet: RJ45




ArcPix:


Sauro CGF 050 M5



Sauro CGM 050 M5



ArcDot/ ArcSource Outdoor 4MC Pixel/ArcDotFlash: Chogori CGRBB-03RFFS-SC8001 (female)




Power: Panel connector IEC C14 (socket)

Power cord IEC C13 included

Operating ambient temperature

-10°C/+40°C (+14°F/104°F)

Dimensions(mm)



Weight

3.4 kg

Accessories

1 x Power cord IEC C13

4 x Screw terminal board Sauro CGM 050 M5

Items needed for installation (quantity depends on size and type of installation)

(P/N 1305 2023) Connection cable, 2m

(P/N 1305 2024) Connection cable, 4m

(P/N 1006 2330) Active Terminator for ArcDot

(P/N 1006 2331) Passive Terminator for ArcDot

(P/N 1305 1703) Ferrite GTFC 16-8-16 (for ArcDot)

(P/N 10062551) Termination Box ArcPix

(P/N 1305 1312) Ferrite CSA19/9.4/29-4S60-EN (for ArcPix)

(P/N 10062550) Connection Box ArcPix (for changing faulty ArcPix)

Specifications are subject to change without notice.

May 24, 2022

Copyright © 2017-2022 Robe Lighting - All rights reserved

Made in CZECH REPUBLIC by ROBE LIGHTING s.r.o. Palackeho 416/20 CZ 75701 Valasske Mezirici

