Anolis
A ROBE Business

Calumma XL MC
Calumma XL SC

USER MANUAL

Version 1.2

Table of contents

> **FOR YOUR OWN SAFETY, PLEASE READ THIS USER MANUAL CAREFULLY**
> **BEFORE POWERING OR INSTALLING YOUR CALUMMA!**
> *Save it for future reference.*

This device has left our premises in absolutely perfect condition. In order to maintain this condition and to ensure safe operation, it is absolutely necessary for the user to follow the safety instructions and warnings written in this manual.

The manufacturer will not accept liability for any resulting damages caused by the non-observance of this manual or any unauthorized modification to the device.

Unauthorized modification will void warranty.

1. Safety instructions

> ***DANGEROUS VOLTAGE CONSTITUTING A RISK OF ELECTRIC SHOCK IS PRESENT WITHIN THIS UNIT!***

This fixture should be operated only from the type of power source indicated on the marking label. If you are not sure of the type of power supplied, consult your authorized distributor or local power company.

Always disconnect the fixture from AC power before servicing or cleaning.

Make sure the power/data cable is not damaged by sharp edges.

Do not install the unit near an open flame.

Refer servicing to qualified service personnel.

This fixture falls under protection class I. Therefore this fixture has to be connected to a mains socket outlet with a protective earthing connection.

Do not connect this fixture to a dimmer pack.

LED light emission. Risk of eye injury. Do not look into the beam from a short distance without suitable protective eyewear. Do not look at LEDs with magnifiers or similar optical instruments that may concentrate the light output.

The fixture was designed for outdoor use. This fixture must not be used for underwater installation.

When choosing the installation spot, please make sure that the fixture is not exposed to extreme heat or dust.

Avoid using the unit in locations subject to possible impacts.

The fixture body never must be covered with cloth or other materials when the fixture is under operation.

Only operate the fixture after having checked that the housing is firmly closed and all screws are tightly fastened.

The fixture becomes hot during operation. Allow the fixture to cool approximately 30 minutes prior to servicing or maintenance.

Operate the fixture only after having familiarized yourself with its functions. Do not permit operation by persons not qualified to operate the fixture. Most damages are the result of unprofessional operation!

Immunity of the equipment is designed for electromagnetic environments E1, E2, E3 according to the standard EN55103-2 ed.2 Electromagnetic compatibility. Product family standard for audio, video, audiovisual and entertainment lighting control apparatus for professional use. Part 2: Immunity.

The product (covers and cables) must not be exposed to a high frequency electromagnetic field higher than 3V/m.

The installation company should check levels of possible interferences above the tested levels E1,E2,E3 given by this standard (e.g. transmitters in surrounding area) before installing the equipment.
Emission of the equipment complies with the standard EN55032 Electromagnetic compatibility of multimedia equipment – Emission Requirements according to class B.

Please consider that unauthorized modifications on the fixture are forbidden due to safety reasons!

Please use the original packaging if the fixture is to be transported.

If this device will be operated in any way different to the one described in this manual, the product may suffer damages and the warranty becomes void. Furthermore, any other operation may lead to dangers like short-circuit, burns, electric shock etc.

2. Fixture exterior view

1. Transparent glass cover
2. Mounting yoke
3. Tilt adjusting lock
4. LED module with heat sink

3. Installation

3.1 Mounting the fixture

The Calumma can be fastened in any orientation on a flat, non-flammable surface by means of mounting yoke (2).

The LED module (4) can be tilted +180°/-180°. Use an Allen key 2.5 for adjusting a LED module position.

> *Ensure that the structure to which you are attaching the fixture is secure.*

3.2 Connection to mains

> *The unit must be installed by a qualified electrician in accordance with all national and local electrical and construction codes and regulations.*
> *This device falls under class one and must be grounded!*

The Calumma is equipped with auto-switching power supply that automatically adjusts to any 50/60Hz AC power source from 120-277 Volts.

3.2.1 Junction box installation

> **The junction box box falls under protection class I . Therefore, every junction box**
> **has to be connected to a mains socket outlet with a protective earthing connection.**

1.Unscrew the four screws (1) from the cover (2) on the junction box to get access to the terminal block (3) and two mounting holes of diameter of 4.6 mm (4).
2. Screw the junction box on a non-flammable flat surface.

3. Connect cables.

The cable gland M20 x 1.5 with a standard seal serves for a cable of diameter of 7-13mm, for smaller diameter of cable (4-8mm) you have to remove the original seal from the cable gland M20x1.5 and use enclosed reducing seal instead of it. The reducing seal for diameter of cable 4-8mm (P/N 13051388) is enclosed in the Junction box. Remove the end cap from the cable gland before passing the cable.

We recommend to apply an adequate layer of the paste LOCTITE 5331 on the plastic holder of the cable gland before inserting it into the body of the gland and an adequate layer of the paste LOCTITE 577 on the thread of the gland body.

Cable gland M20x1.5:

4. Screw the cover (2) back on the junction box.

3.3 Top hat installlation

1. Unscrew the four flat-head screws M3x8 (1) from the front of the Calumma and remove the flange (2).
2. Place the top hat (3) on the Calumma and screw it by means of the four flat-head screws M3x8 (1).

3.4 Half top hat installlation

1. Unscrew the four flat-head screws M3x8 (1) from the front of the Calumma and remove the flange (2).
2. Place the half top hat (3) on the Calumma and screw it by means of the four flat-head screws M3x8 (1).

4. Control and connection options

4.1 DMX or DALI

<u>Example</u>

DMX connection (CE)
IF the 5-cored cable Flamar 3x AWG 16 + 1x (2x AWG 24), (P/N 1305 1508) is used for Calumma connection and connection among junction boxes:

Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
Blue	Neutral (N)	White	Data – (-)
Yellow/Green	GND $\oplus$	Shielding	Data ground (0V)

Up to 32 Calummas can be connected in DMX chain.

DALI connection
IF the 5-cored cable SJTW 5x 14AWG (P/N 1305 3336) is used for Calumma connection and connection among junction boxes:

Core	Connection	Core	Connection
Black	Live (L)	Red	Data
White	Neutral (N)	Orange	Data
Yellow/Green	GND $\oplus$		

Up to 64 Calummas can be connected in DALI network.

4.2 Wireless DMX

<u>Example</u>

Note: This type of connection is available for M, L, XL versions.

DMX connection (CE)
IF the 5-cored cable Flamar 3x AWG 16 + 1x (2x AWG 24), (P/N 1305 1508) is used for Calumma connection:

| Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
Blue	Neutral (N)	White	Data – (-)
Yellow/Green	GND ⏚	Shielding	Data ground (0V)

DMX connection (US)
IF the 6-cored cable SJTW 6x 14AWG, (P/N 1305 3480) is used for Calumma connection:

Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
White	Neutral (N)	Orange	Data – (-)
Yellow/Green	GND ⏚	Blue	Data ground (0V)

4.3 Wireless DMX to wire DMX

Example

Note: This type of connection must have M, L or XL versions as the first luminaire. Next luminaires in a row could be chosen from S, M, L or XL versions.

DMX connection (CE)
IF the 5-cored cable Flamar 3x AWG 16 + 1x (2x AWG 24), (P/N 1305 1508) is used for Calumma connection and connection among junction boxes:

Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
Blue	Neutral (N)	White	Data – (-)
Yellow/Green	GND ⏚	Shielding	Data ground (0V)

Up to 32 Calummas can be connected in DMX chain.

DMX connection (US)
IF the 6-cored cable SJTW 6x 14AWG, (P/N 1305 3480) is used for Calumma connection and connection among junction boxes:

Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
White	Neutral (N)	Orange	Data – (-)
Yellow/Green	GND ⏚	Blue	Data ground (0V)

4.4 Power On/Off

Note: This type of connection is available for Pure White version only. Non dimmable.

4.5 DMX or Ethernet via E-box

The E-box menu allows you to switch connected Calummas to the two modes:

Standard - LED modules are switched to an internal serial connection. DMX addressing of connected LED modules is made automatically (default DMX address = 1), changes can be done by the E-box menu or by RDM.

Pass-Thr - (Pass through). LED modules are switched to an internal parallel connection. DMX addressing of connected LED modules has to be done manually by means of the Robe Universal and the software RDM Manager.

Example with junction boxes
Pass Through mode is intended for this connection. Max. 32 fixtures can be connected to one LED output of the E-Box (Star, Daisy, Lite) in this mode.

Calumma XL

CE version

IF the 5-cored cable Flamar 3x AWG 16 + 1x (2x AWG 24), (P/N 1305 1508) is used for Calumma connection and connection among junction boxes:

| Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
Blue	Neutral (N)	White	Data – (-)
Yellow/Green	GND ⏚	Shielding	Data ground (0V)

US version

IF the 6-cored cable SJTW 6x 14AWG, (P/N 1305 3480) is used for Calumma connection and connection among junction boxes:

Core	Connection	Core	Connection
Black	Live (L)	Red	Data + (+)
White	Neutral (N)	Orange	Data – (-)
Yellow/Green	GND ⏚	Blue	Data ground (0V)

Number of connected Calummas to one E-box output depends on a cable length, power voltage, type of Calumma and E-box operation mode.
The tables below state max. theoretical number of Calummas connected to the one LED output of the E-box.
The tables apply for the **Pass-Through mode of E-boxes**.

Calumma XL MC	Voltage			
Cable length *	120V	190V	230V	277V
10 m	10	17	20	24
20 m	10	17	20	24
30 m	7	17	20	24
50 m	4	11	16	23
70 m	3	8	12	17
100 m	2	6	8	12
200 m	1	3	4	6
500 m	0	1	2	2

Calumma XL SC	Voltage			
Cable length *	120V	190V	230V	277V
10 m	10	16	19	23
20 m	10	16	19	23
30 m	7	16	19	23

Calumma XL

50 m	4	10	15	22
70 m	3	7	11	16
100 m	2	5	8	11
200 m	1	3	4	6
500 m	0	1	2	2

* Cable length is a total cable length between power supply (e.g. E-box) and last connected Calumma.
  Example: Total cable length=L1+L2+L3+L4+L5+L6

Example with IN/OUT cables
Standard mode is intended for this connection.

Note. Combination of Calummas and Emineres is also possible

Connection of leader cables

Input connector
(front view)

Output connector
(front view)

Leader Cable (CE):

Wire	Power Connection	Wire	Data Connection
Brown	Live	Orange	Data -
Blue	Neutral	Purple	Data +
Yellow/Green	Ground (Earth)	Shielding	Data ground (0V)

Fixture´s Amphenol connectors are dust and water protected according to IP 67 by mating with related Amphenol connectors. They cannot stay disconnected outdoor.
The output connector at last fixture in the Calumma chain has to always be covered with the water-tight cap to keep declared IP rating.

The Calumma modules with IN/OUT cables should be connected to the E-box which allows power supply of the Calumma modules and their control.

Do not connect (disconnect) Calummas to the E-box or Booster box and each other when they are under voltage!

When you change any setting of the E-box, disconnect the E-box from power and connect it to power again to activate changes which you have made.

Number of connected Calummas to one E-box output depends on a cable length, power voltage,
type of Calumma and E-box operation mode.

Calumma XL

The tables below state max. theoretical number of Calummas connected to the one LED output of the E-box without Booster boxes. The following table applies for the **Standard mode of E-boxes**.

Calumma XL MC	Voltage			
Cable length *	120V	190V	230V	277V
10 m	10	17	20	24
20 m	10	17	20	24
30 m	7	17	20	24
50 m	4	11	16	23
70 m	3	8	12	17
100 m	2	6	8	12
200 m	1	3	4	6
500 m	0	1	2	2

Calumma XL SC	Voltage			
Cable length *	120V	190V	230V	277V
10 m	10	16	19	23
20 m	10	16	19	23
30 m	7	16	19	23
50 m	4	10	15	22
70 m	3	7	11	16
100 m	2	5	8	11
200 m	1	3	4	6
500 m	0	1	2	2

* Cable length is a total cable length between power supply (e.g. E-box) and last connected Calumma.
 Example: Total cable length=L1+L2+L3

Notice for the E-box Star: The tables above state max. total number of Calummas connected to 6 LED outputs of the E-box Star (or max. number of Calummas connected to one output if the rest of outputs is not connected).

4.5.1 Booster box

To compensate a voltage drop in large installation, the Booster boxes have to be connected in the chain of Calummas (connected IN/OUT method) at every LED output of the E-box.

The following tables give theoretical numbers of Calummas after which the Booster box has to be installed in the chain of Calummas (at one LED output of the E-box). The following table applies for the Standard mode of E-boxes.

Calumma XL MC	Max. number of Calummas XL MC=191			
	Voltage			
Cable length	120V	190V	230V	277V
10 m	10,20	17	20	24
20 m	10,20,30	17,34	20,40	24,48
30 m	7,14,21,28,35,42,49,56…	17,34,51,68	20,40,60,80	24,48,72
50 m	4,8,12,16,20,24,28,3236,40,44,48,52,56….	11,22,33,44,55,66,77,88,99,110…	16,32,48,64,80,96,112,	23,46,69,92,115
70 m	3,6,9,12,15,18,21,24,27,30,33,36,39,42,45,48,51,54,57,60,63,66,69,72…	8,16,24,32,40,48,56,64,72,80,88….	12,24,36,48,56,68,80,92,104…	17,34,51,68,85,102,119 …
100 m	2,4,6,8,10,12,14,16,18,20…	6,12,18,24,30,36 …	8,16,24,32,40,48,56…	12,24,36,48,56,68,80….
200 m	1,2,3,4,5,6,7,8,9,10,11….	3,6,9,12,15,18,21,24,27,30,33,36,39,42,45,48,51,54,57,60,63,66,69,72……	4,8,12,16,20,24,28,32,36,40,44,48,52,56,60,64,68,72,76,80,84….	6,12,18,24,30,36,42…
500 m	-	1,2,3,4,5,6,7,8,9,10,11….	2,4,6,8,10,12,14,16,18,20…	2,4,6,8,10,12,14,16,18,20…

Calumma XL SC	Max. number of Calummas XL SC=191			
	Voltage			
Cable length	120V	190V	230V	277V
10 m	10,20	16	19	23
20 m	10,20,30,40,50	16,32,48	19,38	23,46
30 m	7,14,21,28,35,42,49,56,64…	16,32,48,64	19,38,57,76	23,46.69
50 m	4,8,12,16,20,24,28,32,36,40,44,48,52,56,60,64,68,72,76,80,84….	10,20,30,40,50,60,70,80,90,100…	15,30,45,60,75,90,105..	22,44,66,88,110…
70 m	3,6,9,12,15,18,21,24,27,30,33,36,39,42,45,48,51,54,57,60,63,66,69,72,75,78,81…	7,14,21,28,35,42,49,56,63,70,77,84,91,98…	11,22,33,44,55,66,77,88,99,110,121…	16,32,48,64,80,96,112…

Calumma XL

| 100 m	2,4,6,8,10,12,14,16,18,20...	5,10,15,20,25,30,35,40,45...	8,16,24,32,40,48,56,64,72,80,88,96...	11,22,33,44,55,66,77,88,99,110,121...
200 m	1,2,3,4,5,6,7,8,9,10,11....	3,6,9,12,15,18,21,24,27,30,33,36,39,42,45,48,51,54,57,60,63,66,69,72,75,78,81...	4,8,12,16,20,24,28,3236,40,44,48,52,56,60,64,68,72,76,80,84....	6,12,18,24,30,36...
500 m	-	1,2,3,4,5,6,7,8,9,10,11....	2,4,6,8,10,12,14,16,18,20...	2,4,6,8,10,12,14,16,18,20...

Example: E-box Daisy, Power supply= 230V, Cable length=70m, fixture=Calumma XL SC.
The Booster box has to be connected after every 11th Calumma XL SC (fixture 11 and fixture 22) from 24 fixtures.

4.5.2 Booster box installation

**ALWAYS DISCONNECT THE CALUMMAS FROM MAINS BEFORE
CONNECTING/DISCONNECTING THE BOOSTER BOX.**

**The Booster box falls under protection class I. Therefore, every Booster box
has to be connected to a mains socket outlet with a protective earthing connection.**

1.Unscrew the four screws (1) from the cover (2) on the Booster box to get access to the terminal block (3) and two mounting holes of diameter of 4.6 mm (4).

2. Screw the Booster box on a non-flammable flat surface and connect cables.

3. Connect power cable.

Remove the end cap from the cable gland before passing the power cable.

The cable gland M20 x 1.5 (5) with a standard seal serves for a cable of diameter of 7-13mm, for smaller diameter of cable (4-8mm) you have to remove the original seal from the cable gland M20 x 1.5 and use the enclosed reducing seal instead of it. The reducing seal for diameter of cable 4-8mm (P/N 13051388) is enclosed in the Booster box.

Power connection

	L	N	⏚ (earth)
Core (CE)	Braun	Blue	Green/yellow

We recommend to apply an adequate layer of the paste LOCTITE 5331 on the plastic holder of the cable gland before inserting it into the body of the gland and an adequate layer of the paste LOCTITE 577 on the thread of the gland body.

Cable gland M20x1.5

LOCTITE 577   LOCTITE 5331

End cap

Terminal
block   Plastic holder   Metal
cover   Body of gland   Rubber   nut
                          seal

4. Screw the cover (2) back on the Booster box.

5. Software update

Software update of Calumma module has to be done by means of the software ROBE Uploader running on PC.
The ROBE Uploader is a software for automatized software update of ROBE fixtures. The ROBE Uploader switches Calummas to the update mode automatically.
Please see https://www.robe.cz/robe-uploader/ for more information.

Note: Calumma modules in DALI connection and ON/OFF connection cannot be updated.

The software update depends on a method of Calummas connection.

<u>**DMX or Ethernet connection via E-box**</u>
If the option **Standard** is selected from the menu **E-box mode**, the E-box will be updated including connected Calumma XL modules. You have to use the file <u>EminereEbox.lib</u> in the ROBE Uploader for this operating mode. The Standard mode is usually used in IN/OUT connection (without junction boxes).

If the option **Pass-Thr** is selected from the menu **E-box mode**, you have to do the following steps to update Calummas XL including the E-box. The Pass-Through mode is usually used in connection with junction boxes.
1. Update connected LED modules by means of the file Calumma.lib in the ROBE Uploader.
2. Set the E-box to the Standard mode and switch it off/on. Use the file EminereEbox.lib in the ROBE Uploader for software update of the E-box.
3. After updating the E-box, set the E-box to the Pass-Through mode and switch it off/on.

 For more information about updating please see the E-box Lite/Daisy/Star user manual.

Examples:

1. By means of DMX connection and Robe Universal Interface, IN/OUT connection.

2. By means of the Ethernet connection, IN/OUT connection.

3. By means of DMX connection and Robe Universal Interface. Connection via junction boxes.

If you use a connection via junction boxes and you need to update connected E-box, switch the E-box to the Standard mode and use the EminereEbox.lib in the ROBE Uploader to update E-box. After updating the E-box, switch it back to the Pass-Trough mode.

DMX connection

For updating of Calumma modules, use the file <u>Calumma.lib in the ROBE uploader</u>.

6. Technical specifications

Power supply
- Electronic auto-ranging
- Input voltage: 120 - 277V AC, 50/60 Hz
- Power consumption:
    Calumma XL MC: 175 W
    Calumma XL SC: 185 W

- Inrush current:
    Calumma XL MC: 60A(twidth= 510us measured at 50% Ipeak) at 230VAC, cold start
    Calumma XL SC: 60A(twidth= 510us measured at 50% Ipeak) at 230VAC, cold start

Optic
- Light source:
    Calumma XL MC: 19 x high power multichip LEDs
    Calumma XL SC: 121 x high power single chip LEDs
- Colour variants: RGBW (W - 6500 K), RGBA, PW (W - 3000 K)
- Beam Angle Calumma XL MC:
    Symetrical: 9°, 15°, 25°, 30°, 45°, 65°, 100°
    Bi-symetrical: 10° x 30°, 30° x 10°, 10° x 60°, 60° x 10°, 15° x 45°, 45° x 15°,
        15°x90°, 90°x15°, 30°x60°, 60°x30°, 30°x90°, 90°x30°
- Beam Angle Calumma XL SC:
    Symetrical: 10°, 15°, 25°, 30°, 45°, 65°, 100°
    Bi-symetrical: 10° x 30°, 30° x 10°, 10° x 60°, 60° x 10°, 15° x 45°, 45° x 15°,
        15°x90°, 90°x15°, 30°x60°, 60°x30°, 30°x90°, 90°x30°
   Asymmetrical side, Asymmetrical forward
- Projected Lumen Maintenance: L90B10 >90.000 hrs, Ta = 25°C / 77°F

Compatible drivers
- E-box Daisy
    1 Output
    1 Main power Input
    Control: DMX, Art-Net, sACN , W-DMX control, RDM
    Pixel control
    120-277V Input
    Connection via terminal blocks, inlets via grommet
    IP67

- E-box Star
    6 outputs
    1 Main power Input
    Control: DMX, Art-Net, sACN , W-DMX control, RDM
    Pixel control
    120-277V Input
    Connection via terminal blocks, inlets via grommet
    IP67

- E-box Lite
    1 output
    1 Main power Input
    Control: DMX, W-DMX control, RDM
    Pixel control

Calumma XL

120-277V Input
Connection via screw terminal blocks, inlets via grommet
IP67

Mounting method
- Via yoke
- Adjustability: -180°/+180°

Housing
- High pressure die-cast aluminium body
- Tempered glass

Cooling system
- Convection

Total heat dissipation
- Calumma XL MC: 448 BTU/h (calculated)
- Calumma CL SC: 473 BTU/h (calculated)

Protection factor
- CE: IP 67 (IP 66 junction box)
- US: Suitable for wet location

Impact rating
- IK10

Operating ambient temperature range
- -20°C /+40°C (-4°F /+104°F)

Connection - CE
- DMX connection
  Calumma IN: Flamar 3x AWG 16 + 1 x (2x AWG 24) Standard 1m with bare-end (P/N 1305 1508)
  Interconnecting cables: Flamar 3x AWG 16 + 1 x (2x AWG 24) (P/N 1305 1508)
  Junction box

- Wireless DMX connection
  Calumma IN: Flamar 3x AWG 16 + 1 x (2x AWG 24) Standard 1m with bare-end (P/N 1305 1508)
  Junction box

- Wireless to DMX connection
  Calumma IN: Flamar 3x AWG 16 + 1 x (2x AWG 24), Standard 1m with bare-end (P/N 1305 1508)
  Interconnecting cables: Flamar 3x AWG 16 + 1 x (2x AWG 24) (P/N 1305 1508)
  Junction box

- DALI connection
  Calumma IN: SJTW 5x 14AWG, standard 1m with bare-end (P/N 1305 3336)
  Interconnecting cables: SJTW 5x 14AWG (P/N 1305 3336)
  Junction box

- DMX or Ethernet via E-box and Junction box
    Calumma IN: Flamar 3x AWG 16 + 1x (2x AWG 24), standard 1m with bare-end (P/N 1305 1508)
    Interconnecting cables: Flamar 3x AWG 16 + 1 x (2x AWG 24), (P/N 1305 1508)
    Junction box

- DMX or Ethernet via E-box and IN/OUT cables
    Calumma IN: Leader cable MM (P/N 13053493) with hybrid connector, standard 0.5 m
    Calumma OUT: Leader cable MF (P/N 13053494) with hybrid connector, standard 0.5 m
    Leader cables: Leader Cable FF 2 m (P/N 13053438)
                Leader Cable FF 5 m (P/N 13053440)
                Leader Cable FF 10 m (P/N 13053436)
                Leader Cable FF 25 m (P/N 13053437)
    Jumper cables: Jumper Cable FF/FM 0,25 m (P/N1 3053422)
                Jumper Cable FF/FM 0,5 m (P/N 13053423)
                Jumper Cable FF/FM 1 m (P/N 13053425)
                Jumper Cable FF/FM 2 m (P/N 13053427)
                Jumper Cable FF/FM 3 m (P/N 13053428)
                Jumper Cable FF/FM 5 m (P/N 13053430)
                Jumper Cable FF/FM 10 m (P/N 13053424)

Connection - US
- Wireless DMX connection
    Calumma IN: SJTW 6x 14AWG, standard 1m with bare-end, (P/N 1305 3480)
    Junction box

- Wireless to DMX connection
    Calumma IN: SJTW 6x 14AWG, standard 1m with bare-end, (P/N 1305 3480)
    Interconnecting cables: SJTW 6x 14AWG (P/N 1305 3480)
    Junction box

- DALI connection
    Calumma IN: SJTW 5x 14AWG, standard 1m with bare-end (P/N 1305 3336)
    Interconnecting cables: SJTW 5x 14AWG (P/N 1305 3336)
    Junction box

- DMX or Ethernet via E-box and Junction box
    Calumma IN: SJTW 6x 14AWG ,standard 1m with bare-end (P/N 1305 3480)
    Interconnecting cables: SJTW 6x 14AWG ,(P/N 1305 3480)
    Junction box

Weight
- Calumma XL SC 12.7 kg (28 lbs)
- Calumma XL MC 12.3 kg (27.12 lbs)

Dimensions (All dimensions in mm [inch])

386 [15 3/16"]

Ø356 [14"]

120 [4 3/4"]

404 [15 7/8"]

Junction box

190 [7 1/2"]
125 [4 15/16"]
50 [1 15/16"]
110 [4 5/16"]
80 [3 1/8"]
57 [2 1/4"]
26 [1"]
52 [2 1/16"]
113 [4 7/16"]
Ø 4.6 [3/16"]

Booster box

125 [4 7/8"]

125 [4 7/8"]

33 [1 5/16"]

80 [3 1/8"]

57 [2 1/4"]

52 [2 1/16"]

Ø 4.6[3/16"]

113 [4 7/16"]

Included items
- 1 x Calumma XL MC / Calumma XL SC
- 1 x User manual

Optional accessories
Junction Box for Calumma, 1x Output, Ral 9006 (P/N 10980757)
Junction Box for Calumma, 1x Output, Ral 9011 (P/N 10980714)
Top Hat Calumma XL RAL9011 (P/N 10980735)
Half Top Hat Calumma XL RAL9011 (P/N 10980739)
Tenon Adaptor for Calumma XL
Pole Mount Bracket for Calumma XL

E-box Daisy (P/N 10063655)
E-box Daisy/W (P/N 10063638)
E-box Lite (P/N 10063657)
E-box Lite/W (P/N 10063653)
E-box Star (P/N 10063656)
E-box Star/W (P/N 10063644)

Booster box (P/N 10063712)

7. Cleaning and maintenance

> ***DANGER !***
> ***Disconnect from the mains before starting any maintenance or cleaning work***

Rinse off loose dirt with low pressure water spray. Wash the housing with a soft brush or sponge and a mild, non-abrasive washing detergent. Rinse it.
Maintenance and service operations are only to be carried out by a qualified person.
Should you need any spare parts, please use ROBE OEM parts.

7.1 Disposing of the product
To preserve the environment please dispose or recycle this product at the end of its life according to the local regulations and codes.

8. ChangeLog
This section summarizes changes in the user manual.

Version of manual	Date of issue	Description of changes
1.1	13/10/2022	DMX protocol ver. 1.1 added
1.2	09/01/2023	Software update description changed

Specifications are subject to change without notice.
January 9, 2023
Made in CZECH REPUBLIC by ROBE LIGHTING s.r.o. Palackeho 416/20 CZ 75701 Valasske Mezirici

DMX protocol for Calumma - All sizes - RGBW(A)

Version: 1.1 (16 modes in total)

Mode/Channels in all							Mode 1- RGBW(A)-8bit, Mode 2- RGB 8-bit, Mode 3- full RGBW(A)
1	*2*	*3*	*4*	*5*	*6*	*7-10*	Mode 4- White-full control, Mode 5- Reduced RGBW(A)
4	3	12	3	6	8	Reserved	Mode 6- Reduced RGBW(A)+white control

Mode/channels						DMX Value	Function	Type of control
1	*2*	*3*	*4*	*5*	*6*		RGBW/RGBA/RGB modes	
1	**1**	**1**	**-**	**1**	**1**		**Red**	
						0 - 255	Red LEDs saturation control (0-100%)	proportional
-	**-**	**2**	**-**	**-**	**-**		**Red Fine**	
						0 - 255	Red LEDs saturation control fine	proportional
2	**2**	**3**	**-**	**2**	**2**		**Green**	
						0 - 255	Green LEDs saturation control (0-100%)	proportional
-	**-**	**4**	**-**	**-**	**-**		**Green Fine**	
						0 - 255	Green LEDs saturation control fine	proportional
3	**3**	**5**	**-**	**3**	**3**		**Blue**	
						0 - 255	Blue LEDs saturation control (0-100%)	proportional
-	**-**	**6**	**-**	**-**	**-**		**Blue Fine**	
						0 - 255	Blue LEDs saturation control fine	proportional
4	**-**	**7**	**-**	**4**	**4**		**White (Amber)**	
						0 - 255	White LEDs saturation control (0-100%)	proportional
-	**-**	**8**	**-**	**-**	**-**		**White (Amber) Fine**	
						0 - 255	White LEDs saturation control fine	proportional
-	**-**	**9**	**1**	**-**	**5**		**Green correction**	
						0	Uncorrected white	step
						1-127	Minus green - uncorrected white	proportional
						128	Uncorrected white (128=default)	step
						129-255	Uncorrected white - Plus green	proportional
-	**-**	**10**	**2**	**-**	**6**		**Colour temperature correction (CTC)**	
						0	No function (0 - default)	step
						1 - 10	Tungsten dimming 2700 K	step
						11 - 20	Tungsten dimming 3200 K	step
						21-255	Colour temperature changing from 1800 K --> 6500 K (21-1800K, 66-2700K, 91-3200K,141-4200K, 211-5600K, 255-6500K)	proportional
-	**-**	**11**	**3**	**5**	**7**		**Dimmer**	
						0 - 255	Light intensity coarse (0-100%)	proportional
-	**-**	**12**	**-**	**6**	**8**		**Dimmer Fine**	
						0 - 255	Light intensity fine	proportional

DMX protocol for Calumma - All sizes - MC and SC

Version: 1.1 (16 modes in total)

Mode/Channels in all				TW Modes: Mode 6- White selection + Dimmer, Mode 7- WW + CW	
11	*12*	*13*	*14-16*	PW Mode: Mode 8- Dimmer	
3	4	2	Reserved		

				TW and PW modes		
Mode/channels			DMX Value	Function		Type of control
6	*7*	*8*				
1	-	-		**White colour selection**		
			0 - 255	White from 2700 K - 6500 K		proportional
-	1	-		**Warm White**		
			0 - 255	Warm White LEDs saturation control (0-100%)		proportional
-	2	-		**Cool White**		
			0 - 255	Cool White LEDs saturation control (0-100%)		proportional
2	3	1		**Dimmer**		
			0 - 255	Light intensity coarse (0 - 100%)		proportional
3	4	2		**Dimmer Fine**		
			0 - 255	Light intensity fine		proportional